



Admin & Operational Program Challenges

Chip Matthews, Cross-Connection Program Manager David Moore, Cross-Connection Program Supervisor Adam Clingan, Cross-Connection Program Field Inspector

February 23, 2023



Agenda

- WSSC Water Cross-Connection Control Program Introduction
- Program Manager Administrative & Operational Challenges
- Program Supervisor Viewpoint & Challenges
- Program Field Inspector Viewpoint & Challenges
- Summary



WSSC Water Cross-Connection Control Company & Program Introduction


Vision - To be THE World-Class Water Utility where Excellent Products and Services are Always on TAP!












Operational Area Staffing










<u>Our Authority</u>

- WSSC Plumbing & Fuel Gas Code
- Maryland Department of the Environment
- COMAR 26.04.01.32, 1/1/1986
- Identify, survey, and require testing.



Our Team



- Montgomery County Cross-Connection Staff
- Prince George's County Cross-Connection Staff
- Compliance Supervisor
- Inspection Services Agents
- Work closely with Plumbing Inspection Services Staff
- Other WSSC Water staff attending Introductions

Our Mission





Protect & Serve our WSSC Water Customers





WSSC Water Program Manager Administrative and Operational Challenges



Top 5 Administrative & Operational Challenges – Program Manager View

- Tester field data, knowledge & level of understanding.
- Data integrity.
- Customer creativity.
- Administrative surveys.
- Reminder mailings & returned mail management.



#I - ASSE 1013 Check Valve #2

- Leaking vs. Closed Tight
- A reading for Check Valve #2
- Incorrect submittals lead to our 2nd challenge

Fact! CV #2 must be ≥ 1.0 psi



#2 – Data Integrity

- Duplicate Serial Numbers
- DCVA readings in excess of 10.0 psi

900,000 Combinations for 6 digit numbers using 0-9



#2 – Data Integrity

DOUBLE CHECK VALVE ASSEMBLY

Protects against Low Hazard ONLY! Both springs same, > or = to 1.0 psi

Maximum pressure drop - 10 psi.

Must be tested at least once a year

Check read above 5.0 psid? May be caused by: - Incorrect Spring - Possible RP 1st Check







Double Check Valve Assembly

ASSE 1015

Protects against Low Hazard ONLY!

Both springs same, > or = to 1.0 psi

Maximum pressure drop - 10 psi.

Must be tested at least once a year

#3 – Customer Creativity



A Dual Purpose Shower Head & Coffee Maker?

#4 Administrative Surveys



- Cold Calling
- Customer Sensitivity To Information Release
- Deep Research Survey Forms Stored in Customer Record.

2022 50.3 Billion Robocalls







#5 Reminder Notices



- Reminder Mailings
- Returned Mail Management



WSSC Water Program Supervisor Administrative and Operational Challenges



Top 3 Administrative & Operational Challenges Program Supervisor View

- Employee Training
- Attracting & retaining Master Plumber/Gasfitters that are leaders in their profession
- Customer Education



WSSC Water Program Field Inspector Administrative and Operational Challenges



Top 4 Administrative & Operational Challenges From the Field Inspector's View

- Communicating with a wide range of customers
- Large number of accounts that require field surveys
- Encountering a wide range of water utilizing equipment
- Training new team members





Remembering Don "Doc" Smith 2/10/1952 – 10/17/2022



Closing Comments

- Different challenges and viewpoints.
- Plumbing systems are NOT static.
- No one has seen it all!
- Thank you!







